



中国国家强制性产品认证证书

证书编号：2024010305650918

认证委托人名称及地址

IDEC 株式会社
日本大阪市淀川区西宫原2丁目6番64号

生产者名称及地址

IDEC 株式会社
日本大阪市淀川区西宫原2丁目6番64号

生产企业名称及地址

IDEC 株式会社—滝野工厂
日本国兵庫県加东市河高字黑石 355-18

产品名称和系列、型号、规格

紧急停止开关

AB6E; Ui: 250V;Uimp:2.5kV;Ith:5A; AC-15:Ue:AC250V,Ie:1.5A/0.75A;
DC-13:Ue:DC30V,Ie:1A; 防护等级:工作面 IP65 或 IP40; 安装孔径:Φ16mm.型号解
释详见附页

产品标准和技术要求

GB/T 14048.5-2017

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》
(CNCA-C03-02:2024) 的要求，特发此证。

发证日期：2024年07月02日 有效期至：2029年07月01日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站（www.cnca.gov.cn）查询。



签发：

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010305650918

NAME AND ADDRESS OF THE APPLICANT

IDEC CORPORATION
6-64 Nishimiyahara 2-chome, Yodogawa-Ku, Osaka 532-0004 Japan

NAME AND ADDRESS OF THE MANUFACTURER

IDEC CORPORATION
6-64 Nishimiyahara 2-chome, Yodogawa-Ku, Osaka 532-0004 Japan

NAME AND LOCATION OF THE FACTORY

IDEC CORPORATION - TAKINO PLANT
355-18 Aza-Kuroishi, Kotaka, Kato-Shi, Hyogo 679-0221, Japan

PRODUCT NAME,MODEL AND SPECIFICATION

Emergency stop switch
AB6E; Ui: 250V;Uimp:2.5kV;Ith:5A; AC-15:Ue:AC250V,Ie:1.5A/0.75A; DC-13:Ue:DC30V,Ie:1A;
Levels of Protection : (Working face)IP65 or IP40; Aperture : Φ16mm.See attached page for details

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Jul.02,2024

Valid until: Jul.01,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





中国国家强制性产品认证证书

证书编号：2024010305650918

证书附页：第 1 页 共 1 页

AB6E - 3 BV 01 P T R - *****
1 2 3 4 5 6 7 8

- 基本型号
AB6E
- 按钮尺寸
3 - 30 mm O.D.; 4 - 40 mm O.D.;
- 功能
BV - 非照明
- 主触头（常闭）数量(NC)
01 - 1 NC; 02 - 2 NC;
- 保护等级
无 - IP40; P - IP65;
- 端子形状
无 - 焊接端子; T - 翼片端子(焊接兼用翼片端子);
- 按钮颜色
R - 红色;
RH - 鲜红色;
RM - 鲜红色 (按钮上” →” 表示);
RR - 深红色;
RRM - 深红色 (按钮上” →” 表示);
- 制造厂备案编号(可选) *****: 各种字符

本页为证书附页，应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司