

CERTIFICATE OF COMPLIANCE

Certificate Number 20190305-E211795
Report Reference E211795-20190228
Issue Date 2019-MARCH-05

Issued to: IDEC CORP
6-64 NISHIMIYAHARA 2-CHOME
YODOGAWA-KU
OSAKA 532-0004 JAPAN

**This certificate confirms that
representative samples of**

PROGRAMMABLE CONTROLLERS FOR USE IN
HAZARDOUS LOCATIONS

Class I, Division 2, Groups A, B, C and D
Programmable Display Operating Interface, Model HG2G-
V5FT22 followed by TF, TG, TH or TJ, followed by -W or -B

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 121201, Non-incendive Electrical Equipment for Use in
Class I and II, Division 2 and Class III, Divisions 1 and 2
Hazardous (Classified) Locations
CAN/CSA C22.2 No. 213-17, Nonincendive Electrical
Equipment for Use in Class I and II, Division 2 and Class III,
Divisions 1 and 2 Hazardous (Classified) Locations


Additional Information:

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

