

中国国家强制性产品认证证书

证书编号：2019010303251307

委托人名称、地址

IDEC 株式会社

日本大阪市淀川区西宫原 2 丁目 6 番 64 号

生产者（制造商）名称、地址

IDEC 株式会社

日本大阪市淀川区西宫原 2 丁目 6 番 64 号

生产企业名称、地址

IDEC 株式会社-福崎工厂

日本兵库县神崎郡福崎町西治字拜尾 860-2

产品名称和系列、规格、型号

安全模块

HR5S; Ui:250V; Uimp:4kV; AC-15:Ue/le: AC240V/2A; DC-13:Ue/le: DC24V/1A; lth:3A; 防护等级:IP20. 型号解释详见附件

产品标准和技术要求



GB/T14048.5-2017

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，特发此证。

发证日期：2019 年 11 月 25 日 有效期至：2024 年 11 月 25 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。


本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任：陆梅



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2019010303251307

NAME AND ADDRESS OF THE APPLICANT

IDEC CORPORATION

6-64 Nishimiyahara 2-chome, Yodogawa-Ku, Osaka 532-0004 Japan

NAME AND ADDRESS OF THE MANUFACTURER


IDEC CORPORATION

6-64 Nishimiyahara 2-chome, Yodogawa-Ku, Osaka 532-0004 Japan

NAME AND ADDRESS OF THE FACTORY

IDEC CORPORATION - FUKUSAKI PLANT

860-2 Saiji Aza-Haio Fukusaki-Cho, Kanzaki-Gun, Hyogo-Ken 679-2215 Japan



PRODUCT NAME, MODEL AND SPECIFICATION

Safety Module

HR5S; Ui:250V; Uimp:4kV; AC-15:Ue/Ie: AC240V/2A; DC-13:Ue/Ie: DC24V/1A; Ith:3A; Levels of Protection:IP20. See the Appendix for type explanation

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Nov.25,2019

Valid until: Nov.25,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn




President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

第 1 页 共 1 页

证书编号：2019010303251307

纸 号：2456120

型号的解释：

HR5S - C2 D T025
(1) (2) (3)

HR5S 安全模块

(1) 监测类型和输出回路数量

C2: 用于急停开关和限位开关的监控.2NO.

(2) 产品类型

S-Simple type

B-Basic type

D-OFF-delay type

(3) 关闭延迟时间

Blank-no OFF-delay


T025-0.25 Sec.

T050-0.5 Sec.

T100-1 Sec.

T200-2 Sec.

T400-4 Sec.



注：此附录与证书同时使用时有效。



主 任：

陆梅



中国质量认证中心