

EC Type-Examination Certificate



Product Safety
Functional
Safety

www.tuv.com
ID 060000000

Reg.-No.: 01/205/5739.00/19

Product tested	Safety Relay Module	Certificate holder	IDEC CORPORATION 6-64, Nishimiyahara, 2-Chome Yodogawa-ku Osaka 532-0004 Japan
-----------------------	---------------------	---------------------------	---

Type designation	HR5S Series Details see actual "Revision List"
-------------------------	---

Codes and standards	EN ISO 13849-1:2015 EN ISO 13849-2:2012	EN 60947-5-1:2017 IEC 61000-6-7:2014
----------------------------	--	---

Intended application	The Safety Relay Module complies with the requirements of PL d / Cat. 2 (Basic type / OFF-delay types) and PL c / Cat. 2 (Simple type) of EN ISO 13849-1 and can therefore be used in applications up to these levels.
-----------------------------	--

Specific requirements	The instructions of the associated Installation and Operating Manual shall be considered.
------------------------------	---

It is confirmed, that the product under test complies with the requirements for machines defined in Annex I of the EC Directive 2006/42/EC.

Valid until 2024-11-08

The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/FSP 1956.00/19 dated 2019-11-08.
This certificate is valid only for products which are identical with the product tested.

Köln, 2019-11-08

Notified Body for Machinery, NB 0035

Dipl.-Ing. Eberhard Frejno


www.fs-products.com

www.tuv.com

 **TÜVRheinland**[®]
Genau. Richtig.

TÜV Rheinland Industrie Service GmbH, Am Grauen Stein, 51105 Köln / Germany
Tel.: +49 221 806-2434, Fax: +49 221 806-1354, E-Mail: industrie-service@de.tuv.com

10/201 10.17 D A4 © TÜV, TÜEV und TUV sind eingetragene Marken. Eine Nutzung und Verwendung bedarf der vorherigen Zustimmung.



Revision List

referred to on Certificate No.: 01/205/5739.00/19

Safety Relay Module HR5S Series



Safety related modules / components

Type Designation	Description	HW Version	Report-No.:	Certification Status
HR5S-C2S	Simple type	1.0	968/FSP 1956.00/19	Valid
HR5S-C2B	Basic type	1.0		
HR5S-C2D-T025	OFF-delay (0.25s) type	1.0		
HR5S-C2D-T050	OFF-delay (0.50s) type	1.0		
HR5S-C2D-T100	OFF-delay (1s) type	1.0		
HR5S-C2D-T200	OFF-delay (2s) type	1.0		
HR5S-C2D-T400	OFF-delay (4s) type	1.0		

Safety Manual / User documentation

Document No.	Description	Report-No.:	Certification Status
B-2134(0)	INSTRUCTION SHEET (Original Instructions) Safety Relay Module HR5S Series	968/FSP 1956.00/19	Valid

The content of this Revision List has been agreed between Manufacturer and Certification Body.

Revision:

Date	Rev.	Description / Changes	Author
2019-11-08	1.0	Initial creation, based on Report-No.: 968/FSP 1956.00/19	hs/A-FS

IDEC Corporation

2-6-64 Nishimiyahara, Yodogawa-ku
Osaka 532-0004 / Japan

File: 01_205_5739_00_19_RL_2019_11_08.docx

TÜV Rheinland Industrie Service GmbH
Automation - Functional Safety (A-FS)
Am Grauen Stein
51105 Köln / Germany