

Certificate

No.: BL 97 02 13332 377



Idec Izumi Corporation

7-31, Nishimiyahara-1-Chome
Yodogawa-Ku, Osaka 532
Japan

with production facilities
26305

is authorized to label the following products with the
certification mark E or L
as shown in the certification mark list. See also notes overleaf.

Product: Proximity switch
Photoelectric switches ISF-Series

Model: ISF-T10MU, -T10MTU, -R05MU, -R05MTU, -P03MU,
-P03MTU, -D500U, -D500TU, -MK827

Parameters: Power voltage : 24 - 240V AC, 50/60 Hz
and 24 - 240 DC

Output : Electromechanical relay contact
250 V AC / 1 A, 30 V DC / 2 A

Sensing Range : 10 m: -T10MU, -T10MTU;
5 m: -R05MU, -R05MTU;
3 m: -P03MU, -P03MTU;
0,5 m: -D500U, -D500TU;
30 m: -MK827

Degree of protection : IP66

Remark : Used indicator colour: red
(operating indicator)

Type ..TU with time-delay-function



The product meets the relevant safety requirements and was tested
according to:

approximate to
pr EN 60947-5-2: 1995

Report No: 02136600102

Released with the above certificate number by the
certification body of TÜV PRODUCT SERVICE GMBH.

Department:
Date:

HANEMA3 / Ba
02-21-1997

